




Project: Sound Transmission
Client: Whisper Industries LLC.
Tests: OL08-0708 = QuietClip

OL08-0345 = RSIC-1

QuietClipCompared to RSIC-1

Specimens: Interior wall assembly Method: ASTM Standard E90



	L _n (dB)	
Freq. Hz	QuietClip	RSIC-1
80	24	21
100	26	24
125	35	31
160	35	34
200	41	40
250	48	47
315	53	52
400	56	54
500	57	57
630	59	58
800	62	62
1000	65	64
1250	65	66
1600	62	66
2000	57	59
2500	56	55
3150	58	61
4000	65	67
5000	69	68

Results limited by flanking limit of lab

Assembly Elements

Listed in order from source room to receive room side

0.625 (5/8") gypsum board type x 1.625" screws @ 12" OC

7/8" Hat Channel @ 24" OC

QuietClip(OL08-0708) or RSIC-1 (OL-08-0345)

2x4 Wood Studs 16" OC

Fiberglass Insulation

0.625 (5/8") gypsum board type x 1.625" screws @ 12" OC

QuietClips are manufactured by Whisper Industries under a private label contract. Testing was conducted by a third party, accredited lab, for Whisper Industries. Performance of QuietClips is identical to that of Whisperclips. In no way do these test results act a guarantee, and WCSS makes no warranties, implied or otherwise, as to the performance in the field.






Project: Sound Transmission

Client: Whisper Industries LLC.

Tests: OL08-0708 = QuietClip
OL08-0501 = ISO MAX

QuietClipCompared to ISOMAX

Specimens: Interior wall assembly Method: ASTM Standard E90



	L _n (dB)	
Freq. Hz	QuietClip	ISO Max
80	24	21
100	26	22
125	35	32
160	35	33
200	41	42
250	48	46
315	53	52
400	56	55
500	57	58
630	59	59
800	62	62
1000	65	63
1250	65	65
1600	62	66
2000	57	62
2500	56	57
3150	58	62
4000	65	69
5000	69	71

Results limited by flanking limit of lab

Assembly Elements

Listed in order from source room to receive room side

0.625 (5/8") gypsum board type x 1.625" screws @ 12" OC

7/8" Hat Channel @ 24" OC

QuietClip(OL08-0708) or ISOMAX (OL-08-0501)

2x4 Wood Studs 16" OC

Fiberglass Insulation

0.625 (5/8") gypsum board type x 1.625" screws @ 12" OC

QuietClips are manufactured by Whisper Industries under a private label contract. Testing was conducted by a third party, accredited lab, for Whisper Industries. Performance of QuietClips is identical to that of Whisperclips. In no way do these test results act a guarantee, and WCSS makes no warranties, implied or otherwise, as to the performance in the field.