



ONLINE CERTIFICATIONS DIRECTORY

BLIS.R26312
Caulking and Sealants

SAINT-GOBAIN PERFORMANCE PLASTICS CORP

R26312

1 SEALANTS PARK
GRANVILLE, NY 12832 USA

Sealant material designated Green Glue NoiseProofing Compound™

	Applied to Inorganic Reinforced Cement Board+
Fire Spread	10
Smoke	5

+Tested as applied in three 3/8in. beads 5 in. OC, Covering 6.3 percent of the exposed test sample area.

Last Updated on 2009-07-29

Copyright © 2009 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data(or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright ©2009 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge

